ASC Z97 ANSI ACCREDITED STANDARDS COMMITTEE

Safety Requirements for Architectural Glazing Materials

Chairman: K. Olah, 2300 Harmon Road, Auburn Hills, MI 48326, Phone: 248-340-2141; E-mail: KOLAH@Guardian.com
Secretary: J.C. Schimmelpenningh, 730 Worcester Street, Springfield, MA 01151, Phone: 413-730-3413; E-mail: JCSCHI@eastman.com

Technical Interpretation TI-14.09.001

Document: ANSI Z97.1-2009 Date: September 30, 2014

Referenced Section(s): Section 6.1.(4) Place of fabrication

Interpretation Request: (What needs clarification/modification/removal?) Does having the SGCC number on the logo fulfill 6.1.(4) Place of fabrication?

Request Rationale:

I believe having the SGCC number on the logo fulfills this. Each SGCC number is physical plant specific.

Suggested Revised Language:

No language needed, just an interpretation

Interpretation:

SGCC number on the logo fulfills the requirement of 6.1.(4) Place of fabrication.

Rationale:

The logo is required to demonstrate compliance for the testing and also to identify the manufacturer in the event of a product recall or other need. As long as the manufacturer's name is readable by the lay-person, the plant of manufacture is used for traceability only. Therefore any identification code that is unique per plant of manufacture i.e.: SGCC number, is acceptable.

Keywords: Compliance, label, manufacture, logo

Date of rendered interpretation: October 2, 2014