

ASC Z97 ANSI ACCREDITED STANDARDS COMMITTEE

Safety Requirements for Architectural Glazing Materials

Chairman: K. Olah, 2300 Harmon Road, Auburn Hills, MI 48326, Phone: 248-340-2141; E-mail: KOLAH@Guardian.com
Secretary: J.C. Schimmelpenninck, 730 Worcester Street, Springfield, MA 01151, Phone: 413-730-3413; E-mail: JCSCHI@eastman.com

Technical Interpretation TI-14.09.002

Document: **ANSI Z97.1-2009**

Date: September 30, 2014

Referenced Section(s): Section 6. Marking of Safety Glazing Material

Interpretation Request: (What needs clarification/modification/removal?)

"After having successfully passed the appropriate tests in this standard, like products and materials produced in the same manner as specimens submitted per test shall be legibly and permanently marked with a label."

Request Rationale:

The standard does not specify where on the glass this label needs to be located. As long as the markings are visible and legible, it should not be an issue.

Suggested Revised Language:

For exposed edge glass, it is permissible to mark the edge of the glass.

Interpretation:

Edge marking of glass is permissible for compliance to this standard.

Rationale:

The logo is required to demonstrate compliance for the testing and also to identify the manufacturer in the event of a product recall or other need. As long as the manufacturer's name is readable by the lay-person and contains all the required information, the location of the logo is immaterial to the safety performance as defined in this standard. This statement does not preclude the code official or purchaser from requiring a specific location for a logo.

Keywords: Compliance, label, manufacture, logo

Date of rendered interpretation: October 2, 2014